

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2345/ जल परीक्षण / 77

Dated: 25.06.2025

It is certified that an inspection team headed by Neeraj Kumar (Lab Attendant)

(Name of Officers with designation) from U.P. Jal Nigam Bijhor PHED

inspected the A.A.m. Public School Kiratpur (Bijhor)

(Name & Address of the school) on 23.06.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 83/1135 dated 24.06.2025

of District Level Water Analysis Jal Nigam (PHED Lab) certified that the A.A.m. Public School Kiratpur (Bijhor) (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till



To A.A.m. Public School Kiratpur Bijhor  
(Name & Address of the Institution)

Signature with Seal:   
Name: AKSHAY KUMAR  
Designation: A.E.  
Name & Address of the Office / Department: U.P. Jal Nigam Bijhor UP

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



# Analysis Report

## District Level Water Analysis Laboratory U.P, Jal Nigam Bijnor

Report No. 1135 <b>2345 / 08/06/2025</b>	Date <b>25-06-2025</b>	Page No. <b>77</b>
<b>Customer Details</b>		
Office Name and Address	A.A.M PUBLIC SCHOOL KIRATPUR	
Ref Letter No & date	088/AAMPS/25 DATE-22.06.2025	
<b>Basic details of sample</b>		
District	Bijnor	Block
Gram Panchayat	-----	Village
Habitation	-----	Location
Water Source	Submersible	A.A.M PUBLIC SCHOOL KIRATPUR
Quantity of Sample	1 Lt	Sample No.
Receiving Date	23-06-2025	Date of S.C
Sample Depositor	Neeraj Kumar	Sample Collector
Analysis Start Date	23-06-2025	Sampling Method Used
		IS 17614 (Part 1):2021
		Analysis Completion date- 24-06-2025

Environmental Condition			
Temperature	23.5°C	Relative Humidity	Upto 49.2%

S.R	Analyzed Parameters (Unit of Measurement)	Observed Value	Specified Values as per IS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
2	pH	7.806	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
3	Turbidity (NTU)	1.72	1.0	5.0	IS 3025 P-10:2023
4	TDS(mg/l)	252.0	500	2000	IS 3025 P-16:2023
5	Chloride(mg/l)	15.0	250	1000	IS 3025 P-32:2019
6	Total Alkalinity(mg/l)	195.0	200	600	IS 3025 P-23:2023
7	Total Hardness(mg/l)	252.0	200	600	IS 3025 P-21:2019
8	Calcium(mg/l)	48.84	75	200	IS 3025 P-40:2024
9	Magnesium (mg/l)	32.07	30	100	IS 3025 P-46:2023
10	Nitrate (mg/l)	2.41	45	45	Apha24 th edition -4500 NO <sub>3</sub> <sup>-</sup> Method B (UV Screening Method):2023
11	Sulphate (mg/l)	13.82	200	400	Apha24 th edition-4500 SO <sub>4</sub> <sup>-</sup> Method E (Turbidimetric Method):2023
12	Iron (mg/l)	0.10	1.0	1.0	Apha 24 <sup>th</sup> edition -3500 Fe method B (Phenanthroline Method):2023
13	Fluoride(mg/l)	0.291	1.0	1.5	Apha24th edition-4500 F <sup>-</sup> Method C (Electrode method):2023
14	E.coli	0	Shall not be detectable in 100 ml sample		IS 15185:2016
15	Total Coliform	0	Shall not be detectable in 100 ml sample		IS 15185:2016

**Note -**

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

**Amit**  
prepared By: Lab Technician

**[Signature]**  
Authorized Signatory  
Technical Manager  
(Microbiological)

**[Signature]**  
Authorized Signatory  
Technical Manager  
(Chemical)